

# Energy performance certificate (EPC)

Homestead  
PENYSARN  
LL69 9AJ

Energy rating

G

Valid until: **6 August 2033**

Certificate number: **0030-2669-0381-2607-3441**

Property type

Detached house

Total floor area

96 square metres

## Rules on letting this property



### You may not be able to let this property

This property has an energy rating of G. It cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Properties can be let if they have an energy rating from A to E. The [recommendations section](#) sets out changes you can make to improve the property's rating.

## Energy rating and score

This property's current energy rating is G. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		84 B
69-80	C		
55-68	D		
39-54	E		
21-38	F		
1-20	G	8 G	

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Granite or whinstone, as built, no insulation (assumed)	Very poor
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Flat, limited insulation (assumed)	Very poor
Roof	Roof room(s), no insulation (assumed)	Very poor
Window	Fully double glazed	Average
Main heating	Room heaters, electric	Very poor
Main heating control	Programmer and appliance thermostats	Good
Hot water	Electric immersion, standard tariff	Very poor
Lighting	Low energy lighting in 83% of fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, dual fuel (mineral and wood)	N/A

### Primary energy use

The primary energy use for this property per year is 621 kilowatt hours per square metre (kWh/m<sup>2</sup>).

### Additional information

Additional information about this property:

- Cavity fill is recommended
  - Stone walls present, not insulated
  - Dwelling may be exposed to wind-driven rain
-

## How this affects your energy bills

An average household would need to spend **£6,993 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £5,649 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2023** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

---

### Heating this property

Estimated energy needed in this property is:

- 18,433 kWh per year for heating
- 2,223 kWh per year for hot water

---

### Impact on the environment

This property's current environmental impact rating is G. It has the potential to be D.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year. CO<sub>2</sub> harms the environment.

#### Carbon emissions

An average household produces 6 tonnes of CO<sub>2</sub>

This property produces 10.0 tonnes of CO<sub>2</sub>

---

This property's potential production 3.7 tonnes of CO<sub>2</sub>

---

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

---

### Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Flat roof or sloping ceiling insulation	£850 - £1,500	£271
2. Room-in-roof insulation	£1,500 - £2,700	£1,987
3. Cavity wall insulation	£500 - £1,500	£252
4. Internal or external wall insulation	£4,000 - £14,000	£763
5. Floor insulation (solid floor)	£4,000 - £6,000	£347
6. High heat retention storage heaters	£1,600 - £2,400	£1,937

---

Step	Typical installation cost	Typical yearly saving
7. Solar water heating	£4,000 - £6,000	£92
8. Solar photovoltaic panels	£3,500 - £5,500	£746

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

## More ways to save energy

Find ways to save energy in your home by visiting [www.gov.uk/improve-energy-efficiency](http://www.gov.uk/improve-energy-efficiency).

---

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Shaun Richards
Telephone	07796715304
Email	<a href="mailto:shaunrichards109@btinternet.com">shaunrichards109@btinternet.com</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO011240
Telephone	0330 124 9660
Email	<a href="mailto:certification@stroma.com">certification@stroma.com</a>

### About this assessment

Assessor's declaration	No related party
Date of assessment	1 August 2023
Date of certificate	7 August 2023
Type of assessment	<a href="#">RdSAP</a>

---